

## Appendix C: Certified Validation Report

### Part A: Provided by Validator

#### Audit Information:

Water Supplier Name:  
BIG BEAR CITY CSD

PWS ID:  
3610008

System Type: Potable

Audit Period:  
7/01/2019-6/30/2020

Utility Representation:  
JERRY GRIFFITH, WATER DEPT

Validation Date:  
12/16/2020

Call Time:

Sufficient Supporting Documents Provided:  
YES

#### Validation Findings & Confirmation Statement:

##### Key Audit Metrics:

Data Validity Score: 62 Data Validity Band (Level): LEVEL 3

ILI: 1.02 Real Loss: 132.44 Apparent Loss: 1.91

Non-revenue water as percent of cost of operating system: 5.8%

##### Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. 

*If not, rejected recommendations are included here.*

#### Validator Information:

Water Audit Validator : Colleen Barrette

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided

# Certified Validation Report

**Water System Name:** Big Bear City Community Services District **Water System ID Number:** 3610008 **Water Audit Period:** Fiscal Year 2019/20

## Water Audit & Water Loss Improvement Steps:

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:


We are working on implementing a more vigorous meter testing and auditing program and well as continuing to test our wells for pump efficiency and meter accuracies.

## Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Jerry Griffith

Water Superintendent



12/21/2020